

CONFORMITY TO THE NORM EN 303-5:2012

ACTECO srl has tested on September 25 2012 the heating boilers for solid fuels

LOGIKA 25 – RED LOGIKA 25 REFILL – RED

manufactured by MCZ GROUP S.p.A., via La Croce, 8 - I - 33074 Vigonovo di Fontanafredda (PN) according to the efficiency prescriptions of European standard EN 303-5:2012, with the following results:

Water heat output	Efficiency	CO		NOx as NO ₂		OGC		Dust	
		mg/MJ	mg/Nm ³ (10% O ₂)	mg/MJ	mg/Nm ³ (10% O ₂)	mg/MJ	mg/Nm ³ (10% O ₂)	mg/MJ	mg/Nm ³ (10% O ₂)
kW	(%)								
24,8	96,1	55	113	121	250	1	1	19	39

The boiler complies with

CLASS 5

of the European standard EN 303-5:2012.

The results are listed in the test report Nr. 0545-12NB dated September 26 2012 included in the Technical File of the product.

Cordenons, 26.09.2012

Head of Test Laboratory
dr. Mario Marcuzzi